


**POLLUTION MONITORING DATA  
CULCAIRN SEWAGE TREATMENT WORKS**



**Environment Protection Licence No.:** 3727

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33959&SYSUID=1&LCID=3727>

**Licensee:** Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

**Address of facility:** Cemetery Road, Culcairn NSW 2660

**Monitoring Point 3**

**Location:** Sampling point prior to discharge from effluent pond 2

**Published:** 25 May 2017

**Obtained:** 28 Feb 2017

**Sampled:** 10 Feb 2017

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	5	20	no	
Chlorophyll-a	ug/L	Quarterly	26			
Conductivity	ms/cm	Quarterly	1000			
Faecal Coliforms	cfu/100ml	Quarterly	68		no	
Nitrogen (total)	mg/l	Quarterly	2.5	20	no	
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	9			
Phosphorus (total)	mg/l	Quarterly	6.8	10	no	
Total suspended solids	mg/l	Quarterly	24	30	no	As per Licence condition L2.5 (a) (b)