

Annual Fire Safety Statement

Under the Environmental Planning and Assessment Regulations 2000 – Division 5, Clause 175

Owner's Details

Name: John Smith Brown

Address: 123 Brown Street Jindera

Identification of Building

Lot: 123 DP/SP: 123456 Parish: Jindera

Street No: 123 Street Name: Brown Township: Jindera

Declaration

I: John Smith Brown

of: 123 Brown Street Jindera

Certify that:

- (a) each essential fire safety measure specified in the statement has been assessed by a properly qualified person and was found, when it was assessed, to be capable of performing:
- (i) in the case of an essential fire safety measure applicable by virtue of a fire safety schedule, to a standard no less than that specified in the schedule, or
 - (ii) in the case of an essential fire safety measure applicable otherwise than by virtue of a fire safety schedule, to a standard no less than that to which the measure was originally designed and implemented, and
- (b) the building has been inspected by a properly qualified person and was found, when it was inspected, to be in a condition that did not disclose any grounds for a prosecution under Division 7.

Essential/Critical Fire Safety Measures

Measure/Item	Standard of Performance	Assessment Date
Fire Extinguishers	E1.6 (BCA) & AS 2444	26/01/08
Fire Hose Reels	E1.4 (BCA) & AS 2441	26/01/08
Emergency Lighting	E4.4 (BCA) & AS 2293.1	26/01/08
Emergency Exit Sign	E4.8 (BCA) & AS 2293.1	26/01/08
Fire Hydrant	E1.3 (BCA) & AS 2419.1	26/01/08

Signature: 

Date: 26 January 2008

FIRE & RESCUE NSW REQUESTS A COPY OF THIS STATEMENT BE PROVIDED ELECTRONICALLY IN PLACE OF A HARD COPY BEING POSTED. EMAIL TO: afss@fire.nsw.gov.au