

**POLLUTION MONITORING DATA
HOLBROOK SEWAGE TREATMENT WORKS**



Environment Protection Licence No.: 1804

Link to full licence on EPA website:

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=31289&SYSUID=1&LICID=1804>

Licensee: Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

Address of facility: Bath Street, Holbrook NSW 2644

Monitoring Point 3

Location: Flow meter at the inlet to Sewage Treatment Plant

Published: 12 Sept 2012

Obtained: 31 Aug 2012

Sampled: From 1 July 2012 to 31 Aug 2012

Item	Unit	Frequency	Lowest result	Mean result	Max result	Volume limit	Exceedence (yes/no)	Comments
Daily flow	kl/day	Daily	415	466	965	500	Under review	Wet weather event

Monitoring Point 4 (Representative sample for monitoring points 1 & 2)

Location: Sampling point prior to discharge from effluent tertiary pond

Published: 12 Sept 2012

Obtained: 31 Aug 2012

Sampled: 15 Aug 2012

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	<5	20	no	
Chlorophyll-a	ug/L	Quarterly	<5			
Conductivity	ms/cm	Quarterly	980			
Faecal Coliforms	cfu/100ml	Quarterly	100			
Nitrogen (total)	mg/l	Quarterly	22			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	7.6			
Phosphorus (total)	mg/l	Quarterly	6			
Total suspended solids	mg/l	Quarterly	8	30	no	