

**POLLUTION MONITORING DATA  
HOLBROOK SEWAGE TREATMENT WORKS**



**Environment Protection Licence No.:** 1804

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33960&SYSUID=1&LICID=1804>

**Licensee:** Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

**Address of facility:** Bath Street, Holbrook NSW 2644

**Monitoring Point 4 (Representative sample for monitoring points 1 & 2)**

**Location:** Sampling point prior to discharge from effluent tertiary pond

**Published:** 22 July 2015

**Obtained:** 19 Feb 2015

**Sampled:** 11 Feb 2015

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	7	20	no	
Chlorophyll-a	ug/L	Quarterly	320			
Conductivity	ms/cm	Quarterly	800			
Faecal Coliforms	cfu/100ml	Quarterly	600			
Nitrogen (total)	mg/l	Quarterly	9.9			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	9.7			
Phosphorus (total)	mg/l	Quarterly	4.7			
Total suspended solids	mg/l	Quarterly	48	30	no	As per Licence condition L2.6 (a) (b)