

## Final Fire Safety Certificate

*Under the Environmental Planning and Assessment Regulations 2000 – Division 4, Clause 170*

### Owner's Details

Name: John Smith Brown

Address: 123 Brown Street Jindera

### Declaration

I: John Smith Brown

of: 123 Brown Street Jindera

### Certify that:

each essential fire safety measure specified in the current fire safety schedule for the building to which the certificate relates:

- has been assessed by a properly qualified person; and
- was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.

### Identification of Building

**Lot:** 123      **DP/SP:** 123456      **Parish:** Jindera

**Street No:** 123      **Street Name:** Brown      **Township:** Jindera

### Essential Fire Safety Measures

Measure/Item	Standard of Performance	Assessment Date
Fire Extinguishers	E1.6 (BCA) & AS 2444	26/01/08
Fire Hose Reels	E1.4 (BCA) & AS 2441	26/01/08
Emergency Lighting	E4.4 (BCA) & AS 2293.1	26/01/08
Emergency Exit Sign	E4.8 (BCA) & AS 2293.1	26/01/08
Fire Hydrant	E1.3 (BCA) & AS 2419.1	26/01/08

**Signature:** 

**Date:** 26 January 2008

**Note.** A final fire safety certificate must be provided before a final occupation certificate can be issued for a building under clause 153 (1), and must also be provided if a fire safety order is made in relation to building premises.