

## Supplementary Fire Safety Statement

Under the Environmental Planning and Assessment Regulations 2000 – Division 5, Clause 178

### Owner's Details

Name: John Smith Brown

Address: 123 Brown Street Jindera

### Identification of Building

**Lot:** 123      **DP/SP:** 123456      **Parish:** Jindera

**Street No:** 123      **Street Name:** Brown      **Township:** Jindera

### Declaration

I: John Smith Brown

of: 123 Brown Street Jindera

### Certify that:

Each critical fire safety measure specified in the statement has been assessed by a properly qualified person and was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the statement is issued.

### Essential Fire Safety Measures

Measure/Item	Standard of Performance	Assessment Date
Fire Extinguishers	E1.6 (BCA) & AS 2444	26/01/08
Fire Hose Reels	E1.4 (BCA) & AS 2441	26/01/08
Emergency Lighting	E4.4 (BCA) & AS 2293.1	26/01/08
Emergency Exit Sign	E4.8 (BCA) & AS 2293.1	26/01/08
Fire Hydrant	E1.3 (BCA) & AS 2419.1	26/01/08

Signature: 

Date: 26 January 2008