

EPA Monitoring Data Report

EPL 3727

Culcairn Sewage Treatment Plant
Cemetery Road, Culcairn NSW 2660

Concentration Monitoring

Parameter			Biological Oxygen Demand (mg/L)	Conductivity (uS/cm)	Faecal Coliforms (CFU per 100mL)	Nitrogen (Total) (mg/L)	Oil and Grease (mg/L)	pH (pH)	Phosphorus (Total) (mg/L)	Total Suspended Solids (mg/L)	Chlorophyll A (ug/L)
Point 3 Licence Limit - 100 percentile			20	Not specified	Not specified	20	10	Not Specified	10	30	Not Specified
Point 4,5,6,7,8 Licence Limit - 100 percentile			Not specified	1500	1000	20	Not specified	Not Specified	10	Not Specified	Not specified
Date Sampled	Date Analysed	Date Results Reported									
14/05/2024	1/05/2024	2/05/2024	10	1100	120	9.0	<2	8.1	6.8	19	13
14/02/2024	15/02/2024	29/02/2024	<5	990	1600	2.5	<2	9.2	4.7	32	79
1/11/2023	2/11/2023	16/11/2023	9	910	280	6.2	<2	8.7	4.9	26	11
26/07/2023	27/07/2023	7/08/2023	5	800	15	5.3	<2	8.0	5.4	4	<5
3/05/2023	4/05/2023	16/05/2023	6	570	310	4.7	<2	7.9	6.5	24	6
14/02/2023	15/02/2023	25/02/2023	<5	790	>2400	1.7	<2	10.0	2.6	20	19
9/11/2022			<5	660	<1	2.0	2.00	10.0	3.6	<1	7
2/08/2022			<5	820	<1	4.9	2.00	9.6	4.2	9	9
12/05/2022			<5	860	81	3.3	2.00	8.5	5.6	8	<5
16/02/2022			6	770	2	2.9	2.00	8.2	7.5	6	5
9/11/2021	10/11/2021	23/11/2021	<5	820	<1	1.3	<2	10.5	0.8	8	<5
4/08/2021			5	840	14	3.9	2.00	8.6	4.5	2	7
4/05/2021	5/05/2021	17/05/2021	<5	1000	190	2.9	<2	8.3	5.0	11	14
10/02/2021			7	1100	24000	2.7	2.00	8.5	6.6	11	11
11/11/2020	12/11/2020	24/11/2020	<5	870	150	1.1	<2	9.3	5.2	5	<5
4/08/2020			5	860	8	2.2	2.00	9.1	5.3	6	5