

EPA Monitoring Data Report

EPL 3726

Henty Sewage Treatment Plant  
Comer Street, Henty NSW 2658

Concentration Monitoring

Parameter			Biological Oxygen Demand	Conductivity	Faecal Coliforms	Nitrogen (Total)	Oil and Grease	pH	Phosphorus (Total)	Total Suspended Solids	Chlorophyll A
			(mg/L)	(uS/cm)	(CFU per 100mL)	(mg/L)	(mg/L)	(pH)	(mg/L)	(mg/L)	(ug/L)
Point 1 Licence Limit - 100 percentile			20	Not specified	Not specified	20	10	Not specified	Not specified	30	Not specified
Point 4,5,6,7,8 Licence Limit - 100 Percentile			Not specified	1500	1000	20	Not specified	Not specified	10	Not specified	Not specified
Date Sampled	Date Analysed	Date Results Reported									
14/05/2024	1/05/2024	2/05/2024	19	660	230	5.2	<2	9.1	8.2	72	370
14/02/2024	15/02/2024	29/02/2024	15	750	>2400	3.9	<2	8.8	5.7	46	400
1/11/2023	2/11/2023	16/11/2023	7	700	16	4.3	<2	8.8	6.2	28	190
26/07/2023	27/07/2023	7/08/2023	20	620	3	5.0	<2	9.5	5.4	34	530
3/05/2023	4/05/2023	16/05/2023	33	700	>2400	20.0	<2	8.8	3.4	48	1300
14/02/2023	15/02/2023	25/02/2023	7	780	>2400	2.6	<2	7.2	5.8	34	120
9/11/2022			17	760	1100	7.2	2.00	7.9	2.3	<1	200
2/08/2022			7	780	900	3.3	2.00	7.6	6.0	5	35
12/05/2022			9	790	880	2.9	2.00	7.7	7.5	12	150
16/02/2022			9	660	2400	2.3	2.00	8.3	5.3	26	140
9/11/2021	10/11/2021	23/11/2021	<5	760	1600	2.7	<2	7.9	5.3	14	14
4/08/2021			5	720	110	4.0	2.00	8.1	4.3	8	5
4/05/2021	5/05/2021	17/05/2021	<5	790	550	2.1	<2	7.9	6.7	11	<5
10/02/2021			10	720	3900	3.0	2.00	8.2	5.7	33	54
11/11/2020	12/11/2020	24/11/2020	<5	740	520	1.9	<2	8.4	6.1	21	14
4/08/2020			7	690	88	4.4	2.00	7.8	5.5	18	29