

EPA Monitoring Data Report

EPL 2563

Walla Walla Sewage Treatment Plant
Klemke Avenue, Walla Walla NSW 2659

Concentration Monitoring

Parameter			Biological Oxygen Demand (mg/L)	Conductivity (uS/cm)	Faecal Coliforms (CFU per 100mL)	Nitrogen (Total) (mg/L)	Oil and Grease (mg/L)	pH (pH)	Phosphorus (Total) (mg/L)	Total Suspended Solids (mg/L)	Chlorophyll A (ug/L)
Point 1 Licence Limit - 100 percentile			20	Not specified	Not specified	20	10	Not Specified	10	30	Not Specified
Point 4,5 Licence Limit - 100 percentile			Not specified	1500	1000	20	Not specified	Not Specified	10	Not Specified	Not specified
Date Sampled	Date Analysed	Date Results Reported									
14/05/2024	1/05/2024	2/05/2024	6	860	62	2.2	<2	8.6	7.1	24	59
14/02/2024	15/02/2024	29/02/2024	8	840	>2400	2.8	<2	8.7	7.1	51	100
1/11/2023	2/11/2023	16/11/2023	<5	700	19	1.9	<2	8.2	4.5	16	7
26/07/2023	27/07/2023	7/08/2023	<5	690	4	2.5	<2	7.8	2.6	4	<5
3/05/2023	4/05/2023	16/05/2023	6	700	25	3.7	<2	7.9	7.4	8	<5
14/02/2023	15/02/2023	25/02/2023	9	880	>2400	2.0	<2	7.8	7.5	34	120
9/11/2022			<5	680	26	2.3	<2	7.7	2.0	8	<5
2/08/2022			<5	760	14	1.7	<2	7.8	3.1	6	8
12/05/2022			<5	820	700	2.3	<2	8.0	6.0	15	64
16/02/2022			7	680	1200	1.8	<2	7.8	5.8	16	41
9/11/2021	10/11/2021	23/11/2021	<5	770	>2400	1.1	<2	8.0	5.1	8	<5
4/08/2021			5	710	63	2.5	2.00	8.0	2.4	10	5
4/05/2021	5/05/2021	17/05/2021	<5	850	40	1.8	<2	8.0	7.1	22	14
10/02/2021			10	900	4400	1.4	2.00	7.7	8.9	28	66
11/11/2020	12/11/2020	24/11/2020	<5	730	70	1.3	<2	8.0	5.4	16	15
4/08/2020			5	670	410	2.0	5.00	7.9	4.5	20	5